

Отчет о суточных параметрах  
(01.03.2023 0:00:00 - 10.03.2023 0:00:00)

Объект: Ярославль г, Загородный Сад ул, д. 6 (Психиатрическая больница ); № договора: 324  
Прибор: ВКТ-7 Заводской номер: 00043204  
Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Открытая система отопления, ГВС с циркуляцией (Схема 3)

Дата	t1 °C	t2 °C	dt °C	V1 м3	V2 м3	M1 т	M2 т	Mг т	P1 кг/см2	P2 кг/см2	Qo Гкал	Qg Гкал	ВНР ч	ВОС ч	НС
01.03.2023	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
02.03.2023	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
03.03.2023	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
04.03.2023	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
05.03.2023	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
06.03.2023	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
07.03.2023	69.71	45.75	23.96	9.03	8.72	8.87	8.59	0.28	7.00	7.00	0.223	0.013	14.0	0.0	
08.03.2023	72.78	46.64	26.14	16.19	15.74	15.78	15.50	0.28	7.00	7.00	0.425	0.006	24.0	0.0	
09.03.2023	75.06	47.89	27.17	16.41	15.74	15.96	15.50	0.46	7.00	7.00	0.450	0.018	24.0	0.0	
10.03.2023	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
Средние:	72.52	46.76	25.76	---	---	---	---	---	7.00	7.00	---	---	---	---	
Итого:	---	---	---	41.63	40.20	40.61	39.59	1.02	---	---	1.098	0.037	62.0	0.0	

Дата	V1 м3	V2 м3	M1 т	M2 т	Mг т	Qo Гкал	Qg Гкал	ВНР ч	ВОС ч
06.03.2023	0.00	0.00	0.00	0.00	0.00	0.000	0.000	0.0	0.0
09.03.2023	41.63	40.20	40.61	39.59	1.02	1.098	0.037	62.0	0.0
Итого:	41.63	40.20	40.61	39.59	1.02	1.098	0.037	62.0	0.0

Представитель абонента

Начальник отдела АХЧ Т.В. Шатова 8 915 985 74 26

Представитель энергоснабжающей организации

Шашурова И.Н.\_\_\_\_\_